

Creation du réseau chaleur - HERSTAL

DOCUMENT DE CONSULTATION DES ENTREPRISES

Plan de détail - 9/24

NOM DU FICHIER
RCH HarnM Lcl 2 - Plans - Indice Actes
ECHELLE
1/200

AGENCE ENERGIE
7, rue des Chantiers
78000 VERSAILLES
Téléphone: +33/1-77-71-0
Télécopie: +33/1-77-71-0














SIEGE
31, rue Ferrandière
69289 LYON Cédex 02
Téléphone: +33/4-72-32-56-00
Télécopie: +33/4-78-38-37-85
E-mail: cabinet-merlin@cabinet-merlin.fr

GROUPE MERLIN / Réf. doc.: RCH Herstal Lot 3 - Plans - Indice A - Détail 200ème 9/24

| Ind. | Etabli par: | Vérifié par: | Date: | Objet de la révision |
|------|-------------|--------------|------------|----------------------|
| A | A.SABIO | X.TOUZARD | AVRIL 2020 | PREMIERE EMISSION |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

LEGENDE

| | |
|---|------------------------------------|
|  | Réseau de chaleur |
|  | Vanne de sectionnement réseau |
|  | Purge |
|  | Vidange |
|  | Rivères canalisées |
|  | Réseaux existant - AEP |
|  | Réseaux existant - Unifaire |
|  | Réseaux existant - Eclairage |
|  | Réseaux existant - Electricité |
|  | Réseaux existant - Fibre / Télécom |
|  | Réseaux existant - Gaz |

CHR André Renard
Réf. : H2.10.1
Puissance : 650kW

Raccordi
Ø50

CHR André
Ré
Puiss

Raccordement H2.18
Ø150 Pehd 280

The drawing shows a technical plan view of a road intersection. A yellow triangular warning sign is placed on the road surface. The sign contains the text "Raccordement H2.14" and "Ø125 Pehd 250". The background of the drawing shows a road layout with various colored lines (red, green, blue, yellow) and markers (circles, squares) indicating specific points or features. The sign is oriented diagonally, following the road's alignment.

Pré Madame
Réf. : H2.18
Puissance : 4500kW